Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

[illegible]	:	CP-2018-01-13-01 **Date: 05/02/2018**
[illegible]	:	Assistant Executive Engineer, Project division, BBMP, Bangalore.
[illegible]	:	Project division, BBMP, Bangalore.
[illegible] Name	:	Construction of CC roads and drains 9th main road from 3rd cross to dead end at Attur layout in Ward no.03
[illegible]	:	Sri. Ramesh Y. B , No.34, Down Bazaar Road, Yelahanka, Bangalore-64.
Customer's Reference	:	EE(Project)/Ynk Zone/WO/108/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	13-01-18
Sample ID No	:	2018-01-13-01/04
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	04/02/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	07/01/2018	04/02/2018	149.88 X 150.15 X 150.66	22504	8.147	488.3	21.7	21.6
2	Drain Concrete	M20	07/01/2018	04/02/2018	150.47 X 150.44 X 150.24	22637	8.165	500.3	22.1	
3	Drain Concrete	M20	07/01/2018	04/02/2018	150.65 X 150.44 X 150.47	22664	8.144	473.7	20.9	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in,.civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

[illegible]	:	CP-2018-01-13-01 **Date: 13/01/2018**
[illegible]	:	Assistant Executive Engineer, Project division, BBMP, Bangalore.
[illegible]	:	Project division, BBMP, Bangalore.
[illegible] Name	:	Construction of CC roads and drains 9th main road from 3rd cross to dead end at Attur layout in Ward no.03
[illegible]	:	Sri. Ramesh Y. B , No.34, Down Bazaar Road, Yelahanka, Bangalore-64.
Customer's Reference	:	EE(Project)/Ynk Zone/WO/108/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	13-01-18
Sample ID No	:	2018-01-13-01/01
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	13/01/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	06/01/2018	13/01/2018	151.22 X 150.56 X 150.76	22768	8.264	400.7	17.6	17.9
2	Drain Concrete	M20	06/01/2018	13/01/2018	151.46 X 151.00 X 151.76	22870	8.259	416.2	18.2	
3	Drain Concrete	M20	06/01/2018	13/01/2018	149.86 X 149.68 X 150.64	22431	8.187	401.5	17.9	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

	:	CP-2018-01-13-01 **Date: 03/02/2018**
[illegible]	:	Assistant Executive Engineer, Project division, BBMP, Bangalore.
[illegible]	:	Project division, BBMP, Bangalore.
[illegible] Name	:	Construction of CC roads and drains 9th main road from 3rd cross to dead end at Attur layout in Ward no.03
[illegible]	:	Sri. Ramesh Y. B , No.34, Down Bazaar Road, Yelahanka, Bangalore-64.
Customer's Reference	:	EE(Project)/Ynk Zone/WO/108/2017-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	13-01-18
Sample ID No	:	2018-01-13-01/02
Customer ID	:	Drain Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M20 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	03/02/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Concrete	M20	06/01/2018	03/02/2018	149.33 X 152.01 X 150.26	22700	8.224	513.0	22.6	22.8
2	Drain Concrete	M20	06/01/2018	03/02/2018	151.64 X 150.49 X 151.48	22820	8.179	529.4	23.2	
3	Drain Concrete	M20	06/01/2018	03/02/2018	150.86 X 150.67 X 151.46	22730	8.158	513.7	22.6	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |